

GREATER VISAKHAPATNAM MUNICIPAL CORPORATION
FIRE PREVENTION WING

From:
The Commissioner,
Greater Visakhapatnam
Municipal Corporation,
Visakhapatnam.

To:
The District Educational Officer,
Visakhapatnam District,
Visakhapatnam.

Rc.No.00176/RFO/FPW/GVMC/2021, Dt.02-09-2021

SUB: Greater Visakhapatnam Municipal Corporation - Fire Prevention Wing- Existing Building of M/s.Little Angels School, D.No.1-73-25, Sector-III, MVP Colony, Visakhapatnam - Renewal of Fire No Objection Certificate- Issued - Regarding.

- REF:**
1. Letter Rc.No:5041/B2/97 of Director General, A.P Disaster Response & Fire Services Department, Dated: 12-03-2010.
 2. Delegation orders of the Commissioner, GVMC vide Rc.No.6721/2012/TP. Sec/G1, Dt: 13/09/2019.
 3. This office Fire No Objection Certificate for Occupancy issued vide Rc.No.11291/13/GVMC/FPW, Dt.20-08-2013.
 4. This office Renewal of Fire No Objection Certificate issued vide Rc.No.13553/RFO/FPW/GVMC/2018, Dt.14-12-2018.
 5. Application Dt.15-07-2021 of M/s.Little Angels School, D.No.1-73-25, Sector-III, MVP Colony, Visakhapatnam for Renewal of Fire No Objection Certificate.

*** *** ***

It is to inform that vide reference 3rd cited, the Fire No Objection Certificate for Occupancy was issued to the existing educational building of M/s.Little Angels School, D.No.1-73-25, Sector-III, MVP Colony, Visakhapatnam and vide reference 4th Renewal of Fire No Objection Certificate was also issued.

2) Vide reference 5th cited, an application is received by this office for issuance of Renewal of Fire No Objection Certificate to the same building.

3) Therefore, the Station Fire Officer of Fire Prevention Wing inspected the premises of M/s.Little Angels School, D.No.1-73-25, Sector-III, MVP Colony, Visakhapatnam on 10-08-2021 and submitted the following report.

4) Particulars of the building:

a)	Address of the Premises	M/s.Little Angels School, D.No.1-73-25, Sector-III, MVP Colony, Visakhapatnam
b)	Total Plot Area	4926.56 Sq.Mtrs.
c)	Height of the Building	14.30 Mtrs.
d)	No of blocks/ floors	Stilt + Ground + 03 Upper Floors (Multiple blocks)
e)	Type of occupancy	Educational (School)

5) The floor wise details.

Sl. No.	Floor	Area in Sq. Meters.	Type of Occupancy
1.	Stilt	369.42	Parking
2.	Ground Floor	1675.27	Educational (School)
3.	1 st Floor	1835.27	Educational (School)
4.	2 nd Floor	1835.27	Educational (School)
5.	3 rd Floor	1835.27	Educational (School)
	Total	7550.50	Educational (School)

6) The Builder has provided the following open places all round building.


Direction	Open spaces required as per G.O.Ms.No.168 in Mtrs.	Open space provided (In Mtrs.)	Deficit (In Mtrs.)
East (Front)	4.00	4.50	Nil
West	6.00	2.50	3.50
North	6.00	3.00 + Road	3.00
South	6.00	2.50	3.50

7) Means Escape:

The Management has provided following means of escape

Sl. No.	Details of Staircase	Require Nos./ Mtrs.	Provided Nos./Mtrs.	From	To	Deficit in Mtrs.
1	Internal	1 / 1.50	1.40+1.30 = 2.70	Ground	Terrace	Nil
2	External	1 / 1.50	2 x 1.40 = 2.80	Ground	Terrace	Nil
	Total	2 / 3.00	4 / 5.50			

Contd.



:: 2 ::

8) The details of Occupant Load per unit Exit Width required and provided furnished as below.

Sl. No.	Floor	Build area (Sq.Mtrs.)	Occupancy type	No. of Occupants as per NBC/ Management	Aggregate width of Staircases / Doors Required (Mtrs.)	Aggregate width of Staircases / Doors Provided (Mtrs.)	Deficit
1.	Stilt	369.42	Educational	--	--	--	Nil
2.	Ground Floor	1675.27	Educational	419	4.19	5.50	Nil
3.	1 st Floor	1835.27	Educational	459	4.59	5.50	Nil
4.	2 nd Floor	1835.27	Educational	459	4.59	5.50	Nil
5.	3 rd Floor	1835.27	Educational	459	4.59	5.50	Nil
	Total	7550.50					

9) The Minimum Fire Safety Installations required & provided by the Builder as per the Table-23 of N.B.C of India 2005.

Sl. No.	Fire Safety Measures	Required	Provided	Deficit
1.	Fire Extinguishers as per IS 2190	76 Nos.	76 Nos.	Nil
2.	Hose Reel	09 Nos.	16 Nos.	Nil
3.	Down comer	02 Nos.	02 Nos.	Nil
4.	Terrace Tank	15,000 Ltrs.	25,000 Ltrs.	Nil
5.	Booster Pump	900 LPM	900 LPM	Nil

10) The management has remitted an amount of Rs.2,07,639/- at Soukaryam counter vide challan No.2021-CH-05364, Dt.16-07-2021 towards fire precautionary fees and penal interest.

11) The Fire safety systems were tested by the Station Fire Officer, Fire Prevention Wing, GVMC during the inspection and performance found satisfactory and recommended for issuance of Renewal of Fire No Objection Certificate.

12) Therefore, Renewal of Fire No Objection Certificate is hereby issued to the Educational Building of M/s.Little Angels School, D.No.1-73-25, Sector-III, MVP Colony, Visakhapatnam subject to the following conditions:

i.	All the protection arrangements shall be maintained in good condition as seen during inspection
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached
iii.	All the occupants must know the correct method of operation of the fire fighting system installed
iv.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v.	All students / staff members of the institution shall be trained to operate the fire safety equipments during Emergency.
vi.	Addition / alteration, if any in the building may be obtained with prior permission from this department.
vii.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

13) The Renewal of Fire No Objection Certificate issued to M/s.Little Angels School, D.No.1-73-25, Sector-III, MVP Colony, Visakhapatnam is valid from 14-12-2019 to 13-12-2024 and the Management shall submit the application for Renewal of Fire No Objection Certificate two (2) months before the date of expiry.

14) The issuing of Fire NOC without any prejudice to take action by GVMC against Unauthorized Construction, if any made.

(D.Niranjan Reddy)

Regional Fire Officer
Fire Prevention Wing

Greater Visakhapatnam Municipal Corporation,
Visakhapatnam

Copy to:

1) The Chief City Planner, GVMC, Visakhapatnam.

2) Copy to the management, M/s.Little Angels School, D.No.1-73-25, Sector-III, MVP Colony, Visakhapatnam.

Signed by Danda Niranjan Reddy

Date: 02-09-2021 13:20:52

Reason: Approved

PRINCIPAL

Little Angels School
MVP Colony, Visakhapatnam-17

CHAIRMAN

LITTLE ANGELS (EM) SCHOOLS
M.V.P. Colony / Ukkunagarm,
Visakhapatnam

